

The temporary use or exhibition of petroleum powered motor vehicles or equipment shall conform to the following:

- A. Written permission shall be obtained from the Fire Department seven days prior to use or exhibition of any gasoline-powered motor vehicle.
- B. The installation or operation of all equipment shall be under the supervision of a competent operator. (Live demonstration of equipment powered by combustible fuels requires full description of program before permission can be considered.)
- C. Fire Department personnel shall be employed by the exhibitor whenever engines are to be used or entered into the building. Where such personnel are required, the Fire Department shall determine the following:
 - The number of personnel (a supervisor shall be required when more than one man is employed.)
 - The hourly wage rate.
- D. The maximum amount of fuel permitted to retain in a tank shall be three gallons for gasoline vehicles and ten gallons for diesel vehicles.
- E. A locking type gas cap shall be installed on all gas tanks, and shall be sealed in a manner approved by the Fire Department to prevent the escape of vapors.
- F. All batteries shall be disconnected while the vehicle is not in actual use.
- G. Fueling or defueling of vehicles shall not occur within the building and shall be dispensed or removed with approved safety equipment.

Permit for Temporary Use or Display of Gasoline or Diesel Motorized Vehicles/Equipment Continued

PERMIT REQUEST

We are requesting permission to display or temporarily use gasoline or diesel-powered vehicles and equipment listed below:

Quantity	Type and Description of Vehicle/Equipment
_____	_____
_____	_____
_____	_____
_____	_____

We will arrive at _____ AM/PM _____
Month Day Year

Our representative in charge of the display will be:

This individual will be responsible for reporting to the Fire Department personnel for clearance to enter the building.

NOTE: Fire Department will invoice Exhibitor for their personnel wages. No vehicles or equipment will be permitted into the Kiwanis 4-H Ice Center without Lewis & Clark Home Builders Association inspection and permission.

Name of Event: _____ Date of Event: _____ Booth #: _____

Firm Name: _____ Phone: _____

Address: _____

City: _____ State: _____ Zip Code: _____

Signature: _____ Date: _____